

Inspection Report Bracelet Probe™ Inspection (Customer Name)

Gallery # 1, # 2 and # 3

PICA: Bracelet Probe Final Report

(Customer Adress)

PICA USA Denver, Colorado USA

Field Crew	Allen Russell, Paul Ryhanen, and Dylin Russell
Data Analyst	Allen Russell
Inspection Dates	March 6-13, 2024
Reviewer	David Russell
Report Date	March 21, 2024
Revision	0.2

Table of Contents

Gallery # 1, # 2 and # 3	
Inspection Test Site Information	4
Inspection Results	5
Gallery 2 (South end) - Day 1	6
Gallery 2 (North end) - Day 2	7
Gallery 2 (North end) - Day 3	8
Gallery 1 (South end) - Day 4	9
Gallery 1 (North end) - Day 5	10
Gallery 3 - Day 6	11
Digital Pictures of Types of Piping	12
Digital Pictures of Types of Piping	13
Digital Pictures of Types of Piping	14
Digital Pictures of Types of Piping	15
Inspection Test Site Details	16
Summary of Inspection Results: PR#15: Basin 3: Vertical 4	17
Screen Captures: PR#15: Basin 3: Vertical 4	18
Screen Captures: PR#15: Basin 3: Vertical 4	19
Digital Pictures: PR#15: Basin 3: Vertical 4	20
Inspection Test Site Details	21
Summary of Inspection Results: PR#23: Basin 4: Vertical 4	22
Screen Captures: PR#23: Basin 4: Vertical 4	24
Screen Captures: PR#23: Basin 4: Vertical 4	25
Screen Captures: PR#23: Basin 4: Vertical 4	26
Screen Captures: PR#23: Basin 4: Vertical 4	27
Digital Pictures: PR#23: Basin 4: Vertical 4	28
Digital Pictures: PR#23: Basin 4: Vertical 4	29
Inspection Test Site Details	30
Summary of Inspection Results: PR#2: Basin 4: Vertical 11	31

Screen Captures: PR#2: Basin 4: Vertical 11	. 32
Digital Picture: PR#2: Basin 4: Vertical 11	. 33
Digital Picture: PR#2: Basin 4: Vertical 11	. 34

Inspection Test Site Information

Bracelet Probe [™] Inspection						
Site information						
		Comments				
Date Inspected:	March 6-13, 2024					
Site ID:	Gallery # 1, #2, and #5					
Location:	XXX	XXX				
GPS or Google map coordinates:	XXX					
Pipe Size:	14 and 18 inches	1991 = 28 years old				
Material Type:	Ductile Iron					
	Pressure Class 53					
Class:	(Record Drawings)	Provided by Client				
	14" = 0.420"					
Nominal Wall Thickness:	18" = 0.440"	(Record Drawings)				
Lining Details: internal	Cement Mortar					
Coating Details: external	Factory brown coating					
Excavation Depth:	NA					
Scan Length:	Various					
Scan performed in Flow Direction:	Yes					
Weather:	Not applicable, inside					
Excavation Wetness:	Not applicable, inside					
Soil Type:	Not applicable, inside					
Photos Taken:	Yes					
Piping painted, and rubber coated after buffing:	Yes					
Other observations:						

Note: Pipe classes used throughout this report are in accordance with ANSI/AWWA standards.

See Pipe Class/Thickness table at end of Appendix-3

Inspection Results

The report is divided into 6 days of scanning. Each day has been delegated to a certain section of piping. This has been listed with the Gallery number and direction location (North – South). PICA was supplied with a Plan View and Elevation Map of the areas to inspect. As information was related to (Company) the inspection plan was adjusted accordingly.

Ultrasonic Thickness (UT) measurements were taken at a few selected locations based on Bracelet Probe scan data. The lowest UT measurement found on the pipe has been listed in the following 6 Tables with a location description column for that individual pipe. This individual pipe inspection has also been designated a Pipe Report #.

Additional UT measurements were also performed next to the flange on these pipes, which covered an area from the flange outwards 4 inches and covered around the circumference of the pipe. Any additional UT areas have also been listed. These also cover the bottom flange on the vertical pipes.

The following scale is used for wall loss description: (based on the nominal wall thickness)

Minor: up to - 20% depth. (Could be caused by mill tolerance) **Moderate**: 21% - 40% depth. (Likely caused by pitting corrosion) **Advanced**: 41% - 70% depth. (Likely caused by pitting corrosion)

Severe Corrosion: 71% - 100% depth. (Likely caused by pitting corrosion)

BP Report # 1 with the calibration pipe has been completed and attached. It can be used as a reference for the type of information which is gathered for each pipe. All information is kept on file for each pipe. BP Report # 1 will also explain how the pipe was scanned and the technology background. As mentioned in BP Report #1, the pipes have been marked up with Circumferential and Axial distances. These markings can also be seen in the digital pictures shown later in this report. The areas which were chosen for UT inspection had the external coating buffed off for inspection. After the UT inspection these areas were painted black and recoated.

Three pipes have been chosen to show as an example the information used by the technician analyzing the data. These three pipes are PR#15, PR#23, and PR#2 and are described with the information at the end of this report.

Gallery 2 (South end) - Day 1

Pipe Size	Pipe Report #	Location Description	Low UT thickness readings (inch)	% Wall loss	Description	Near Flange: Low UT thickness readings (inch)
14"	2	Basin 4 - V11	0.105	75%	Severe Corrosion	0.105 same as Scan
18"	3	Basin 4 - MPS10	0.416	6%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
18"	4	Basin 3 - MPS10	0.411	7%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
14"	5	Basin 3 - H9	0.378	10%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
14"	6	Basin 4 - C8	0.361	14%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
14"	7	Basin 3 - C8	0.355	15%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
14"	8	Basin 4 - H9	0.380	10%	Minor Corrosion / Mill tolerance	not available
Additio	nal UT Insp	ection by Flange	Area of coverage: Flange to 4" high			1
14"		Basin 4 - V10	0.308	27%	Moderate corrosion	
14"		Basin 3 - V10	0.187	55%	Advanced corrosion	
Visual II	nspection					<u> </u>
14"		Basin 4 - V9	Leak	100%	Severe corrosion	Also 0.137" by flange
14" non	ninal = 0.42	0"				
18" non	ninal = 0.44	.0"				

Gallery 2 (North end) - Day 2

Pipe Size	Pipe Report #	Location Description	Low UT thickness readings (inch)	% Wall loss	Description	Near Flange: Low UT thickness readings (inch)
14"	9	Basin 3 - V1	0.381	9%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
14"	10	Basin 3 - V2	0.355	15%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
14"	11	Basin 3 - H2	0.393	6%	Minor Corrosion / Mill tolerance	0.405
14"	12	Basin 3 - C3	0.366	13%	Minor Corrosion / Mill tolerance	not available
18"	13	Basin 3 - MPS3	0.410	7%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
18"	14	Basin 3 - MPS2	0.392	12%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
14"	15	Basin 3 - V4	0.256	39%	Moderate Corrosion	Minor corrosion < 10%
14"	16	Basin 3 - V3	0.360	14%	Minor Corrosion / Mill tolerance	Minor corrosion < 10%
Additio	Additional UT Inspection by Flange					
14" noi	minal = 0.42	0"				
18" noı	minal = 0.44	0"				

Gallery 2 (North end) - Day 3

Pipe Size	Pipe Report #	Location Description	Low UT thickness readings (inch)	% Wall loss	Description	Near Flange: Low UT thickness readings (inch)
14"	17	Basin 4 - V1	0.410	2%	Minor Corrosion / Mill tolerance	see below
14"	18	Basin 4 - H1	0.379	9%	Minor Corrosion / Mill tolerance	not available
14"	19	Basin 4 - C1	0.317	24%	Moderate Corrosion - numerous pitting	
14"	20	Basin 4 - V2	0.371	11%	Minor Corrosion / Mill tolerance	see below
14"	21	Basin 4 - V3	0.363	14%	Minor Corrosion / Mill tolerance	see below
14"	22	Basin 4 - H2	0.393	6%	Minor Corrosion / Mill tolerance	0.400
14"	23	Basin 4 - V4	0.279	33% and 45%	Moderate to Advanced Corrosion	see below
14"	24	Basin 4 - V5	0.365	13%	Minor Corrosion / Mill tolerance	see below
Addi	Additional UT Inspection by Flange		Area of coverage: Flange to 4" high			
14"		Basin 4 - V5	0.355	15%	Minor Corrosion / Mill tolerance	
14"		Basin 4 - V4	0.232	45%	Advanced corrosion	This area had an additional 15 inches of UT inspection from the flange
14"		Basin 4 - V3	Leak	100%	Severe corrosion	
14"		Basin 4 - V2	0.406	3%	Minor Corrosion / Mill tolerance	
14"		Basin 4 - V1	0.410	2%	Minor Corrosion / Mill tolerance	Visual: Threads are showing
	inal = 0.420 inal = 0.440					

Gallery 1 (South end) - Day 4

Pipe Size	Pipe Report #	Location Description	Low UT thickness readings (inch)	% Wall loss	Description	Near Flange: Low UT thickness readings (inch)
14"	25	Basin 2 - C9	0.383	9%	Minor Corrosion / Mill tolerance	0.410
14"	26	Basin 2 - H9	0.353	16%	Minor Corrosion / Mill tolerance	0.393
14"	27	Basin 1 - H9	0.397	5%	Minor Corrosion / Mill tolerance	0.450
14"	28	Basin 1 - C9	0.440	0%	Minor Corrosion / Mill tolerance	NA - out of reach
14"	29	Basin 1-2: RAS10	0.388	8%	Minor Corrosion / Mill tolerance	0.398
14"	30	Basin 1-2: RAS9	0.373	11%	Minor Corrosion / Mill tolerance	0.405
14"	31	Basin 2 - H9 North side	0.375	11%	Minor Corrosion / Mill tolerance	0.430
Addition	Additional UT Inspection by Flange		Area of coverage: Flange to 4" high			
14"		Basin 1 - V9	0.050	88%	Severe corrosion	
14"		Basin 1 - V10	0.229	45%	Advanced corrosion	
14"		Basin 1 - V11	0.190	54%	Advanced corrosion	
14"		Basin 2 - V9	0.070	83%	Severe corrosion	
14"		Basin 2 - V10	0.248	40%	Advanced corrosion	
14"		Basin 2 - V11	0.125	70%	Advanced corrosion	
14"		Basin 2 - V8	0.377	10%	Minor Corrosion / Mill tolerance	
	 ninal = 0.42 ninal = 0.42]	
14 11011	iiiiai – 0.42	0				

Gallery 1 (North end) - Day 5

Pipe Size	Pipe Report #	Location Description	Low UT thickness readings (inch)	% Wall loss	Description	Near Flange: Low UT thickness readings (inch)
14"	32	Basin 2 - C2	0.368	12%	Minor Corrosion / Mill tolerance	0.398
14"	33	Basin 1 - C2	0.389	7%	Minor Corrosion / Mill tolerance	0.400
14"	34	Basin 1 - H3	0.386	8%	Minor Corrosion / Mill tolerance	0.440
14"	35	Basin 1 - V4	0.420	0%	Minor Corrosion / Mill tolerance	see below
14"	36	Basin 1 - V3	0.426	0%	Minor Corrosion / Mill tolerance	see below
14"	37	Basin 2 - V3	0.375	11%	Minor Corrosion / Mill tolerance	see below
14"	38	Basin 2 - V1	0.393	6%	Minor Corrosion / Mill tolerance	see below
14"	39	Basin 1 - V1	0.374	11%	Minor Corrosion / Mill tolerance	see below
14"	40	Basin 1 - V2	0.395	6%	Minor Corrosion / Mill tolerance	see below
14"	41	Basin 1 - H2	0.368	12%	Minor Corrosion / Mill tolerance	0.429
Addition	nal UT Inspe	ection by Flange	Area of coverage: Flange to 4" high			
						Average wall
14"		Basin 1 - V1	0.381	8%	Minor Corrosion / Mill tolerance	0.410
14"		Basin 1 - V2	0.441	NA	Minor Corrosion / Mill tolerance	0.480
14"		Basin 1 - V3	0.347	17%	Minor Corrosion / Mill tolerance	0.480
14"		Basin 1 - V4	0.390	7%	Minor Corrosion / Mill tolerance	0.410
14"		Basin 2 - V1	0.440	NA	Minor Corrosion / Mill tolerance	0.480
14"		Basin 2 - V2	0.470	NA	Minor Corrosion / Mill tolerance	0.490
14"		Basin 2 - V3	0.480	NA	Minor Corrosion / Mill tolerance	0.500
14"		Basin 2 - V4	0.230	45%	Advanced corrosion	
	inal = 0.42					
18" nom	ninal = 0.44	0"				

Gallery 3 - Day 6

Pipe Size	Pipe Report #	Location Description	Low UT thickness readings (inch)	% Wall loss	Description	Near Flange: Low UT thickness readings (inch)
14"	42	Basin 5 - C9	0.370	12%	Minor Corrosion / Mill tolerance	0.355 = 15%
14"	43	Basin 5 - H9	0.420	0%	Minor Corrosion / Mill tolerance	0.435
14"	44	Basin 5 - V1	0.377	10%	Minor Corrosion / Mill tolerance	see below
14"	45	Basin 5 - V2	0.410	2%	Minor Corrosion / Mill tolerance	see below
14"	46	Basin 5 - H2	0.367	13%	Minor Corrosion / Mill tolerance	0.440
14"	47	Basin 5 - C2	0.330	21%	Moderate corrosion	0.332
14"	48	Basin 5 - V4	0.359	15%	Minor Corrosion / Mill tolerance	see below
Additio	nal UT Insp	ection by Flange	Area of coverage:	Flange to 4" high		
				<u> </u>		Average wall
14"		Basin 5 - V1	0.334	20%	Minor corrosion- on tapered edge	no corrosion on pipe (0.420)
14"		Basin 5 - V2	0.300	29%	Moderate corrosion- on tapered edge	no corrosion on pipe (0.415)
14"		Basin 5 - V3	0.264	37%	Moderate corrosion	0.410
14"		Basin 5 - V4	0.420	0%	Minor Corrosion / Mill tolerance	0.480
14"		Basin 5 - V5	0.326	22%	Moderate corrosion- on tapered edge	no corrosion on pipe (0.427)
14"		Basin 5 - V9	0.127	70%	Severe corrosion	Visual: Leaking at threads
14"		Basin 5 - V10	0.353	16%	Minor Corrosion / Mill tolerance	0.430
14"		Basin 5 - V11	0.260	38%	Moderate corrosion	0.430
Note: There are 2 bolts on the support beam next to B5-H2 which are loose. These have been marked with arrows and labeled with a yellow marker. 14" nominal = 0.420" 18" nominal = 0.440"						

Digital Pictures of Types of Piping


The following pictures show the 5 Main groups of piping: MPD Header, Vertical Discharge, Cell Inlet, MPS – Mixing Pump Suction, and the RAS line





The top picture shows an example of the MPD Header and the bottom picture shows the Cell Inlet piping.

Digital Pictures of Types of Piping



The picture above shows an example of the Vertical Discharge piping.

Digital Pictures of Types of Piping





The pictures above show an example of the 18" MPS – Mixing Pump Suction piping.

Digital Pictures of Types of Piping





The pictures above show an example of the RAS piping.

Inspection Test Site Details

Example Information for Day 2; for Gallery 2: Pipe Report # 15: Basin 3: Vertical 4

The Zero Foot Reference (ZFR) was set on the pipe, as shown in Figure A1. The ZFR was 0 foot 10 inches from the inside of the bottom end flange. Five scans were performed from 0" to +48.00". Note: Further set up details can be found in BP Report # 1.

Bracelet Probe TM (BP) data for this pipe was labeled as follows:

Bracelet Probe™ Inspection							
Scan Information	n						
Scan	Probe	Circumference	Scan				
Identification	Center	Distance (inches)	Distance	Comments			
S01-01	0	48.0 to 0 to 4.5	5′ 11″	ZFR is 10 inches from flange			
S02-01	9	4.5 to 13.5	5′ 11″	ZFR is 10 inches from flange			
S03-01	18	13.5 to 22.5	5′ 11″	ZFR is 10 inches from flange			
S04-01	27	22.5 to 31.5		Not scanned - inaccessible			
S05-01	36	31.5 to 40.5	5′ 11″	ZFR is 10 inches from flange			
S06-01	45	40.5 to 48.0	5′ 11″	ZFR is 10 inches from flange			

All scans were performed with the flow direction. On the following pages the screen captures show some examples of the data scans. Some of these scans have also been labeled with arrows providing extra information.

Digital pictures showing the marking of the pipe have also been included.

Summary of Inspection Results: PR#15: Basin 3: Vertical 4

Table-1, Summary of Thickness Results

Circumference	Axial	Specified	UT Low	Scan
Location	Distance	Nominal	Reading	Number
0"	0'	0.420"	0.256"	S01-01
0"	0'	0.420"	0.260	S01-01
45"	5'	0.420"	0.408"	S06-01

Ultrasonic Thickness (UT) measurements at a few selected locations based on BP scan data are listed in Table 1.

UT = Ultrasonic Thickness.

The lowest UT measurement was 0.256" at 0' 0".

The pipe at this location exhibits Moderate internal corrosion (pitting) at 39%.

Calculation of % wall loss is against the record nominal, of Class 53, (0.420" wall).

The following scale is used for wall loss description:

Minor: up to - 20% depth. (Could be caused by mill tolerance) **Moderate**: 21% - 40% depth. (Likely caused by pitting corrosion) **Advanced**: 41% - 70% depth. (Likely caused by pitting corrosion)

Severe Corrosion: 71% - 100% depth. (Likely caused by pitting corrosion)

Screen Captures: PR#15: Basin 3: Vertical 4





Figure 1 (Scan S01-01) BP data for a scan covering 48.0" to 0" to 4.5" circumference. (Probe centered at +0" position)



Note: The image above has been labeled showing some of the signals confirmed with UT.

Screen Captures: PR#15: Basin 3: Vertical 4




Figure 2. (Scan S05-01) BP data for a scan covering 31.5" to 40.5" circumference (Probe centered at 36" position).




Figure 3. (Scan S06-01) BP data for a scan covering 40.5" to 49.5" circumference (Probe centered at 45" position).

Digital Pictures: PR#15: Basin 3: Vertical 4




Figure A1. The picture above shows an overview of the pipe.

Inspection Test Site Details

Example Information for Day 3; for Gallery 2: Pipe Report # 23: Basin 4: Vertical 4

The Zero Foot Reference (ZFR) was set on the pipe, as shown in Figure A2. The ZFR was 0 foot 10 inches from the inside of the bottom end flange. Four scans were performed from 0" to +48.00". Note: Further set up details can be found in BP Report # 1.

Bracelet Probe TM (BP) data for this pipe was labeled as follows:

Bracelet Probe™ Inspection				
Scan Information	n			
Scan Identification	Probe Center	Circumference Distance (inches)	Scan Distance	Comments
S01-01	0	48.0 to 0 to 4.5	5′ 11″	ZFR is 10 inches from flange
S02-01	9	4.5 to 13.5	5′ 11″	ZFR is 10 inches from flange
S03-01	18	13.5 to 22.5		Not scanned - inaccessible
S04-01	27	22.5 to 31.5		Not scanned - inaccessible
S05-01	36	31.5 to 40.5	5′ 11″	ZFR is 10 inches from flange
S06-01	45	40.5 to 48.0	5′ 11″	ZFR is 10 inches from flange

All scans were performed with the flow direction. On the following pages the screen captures show some examples of the data scans. Some of these scans have also been labeled with arrows providing extra information.

Digital pictures showing the marking of the pipe have also been included.

Summary of Inspection Results: PR#23: Basin 4: Vertical 4

Table-1, Summary of Thickness Results

Circumference	Axial	Specified	UT Low	Scan
Location	Distance	Nominal	Reading	Number
0"	4"	0.420"	0.279"	S01-01
9"	4"	0.420"	0.293"	S02-01
13"	4'7"	0.420"	0.284"	S02-01
36"	3'0"	0.420"	0.380"	S05-01
36"	4'2"	0.420"	0.287"	S05-01
36"	5'6"	0.420"	0.400"	S05-01
45"	3"	0.420"	0.288"	S06-01

Ultrasonic Thickness (UT) measurements at a few selected locations based on BP scan data are listed in Table 1.

UT = Ultrasonic Thickness.

The lowest UT measurement indicated at first was 0.279" at 4" and after further investigation 0.232" at 1".

The pipe at this location exhibits Moderate internal corrosion (pitting) at 33% and 45% with the used above low UT measurements.

Calculation of % wall loss is against the record nominal, of Class 53, (0.420 wall").

The following scale is used for wall loss description:

Minor: up to - 20% depth. (Could be caused by mill tolerance) **Moderate**: 21% - 40% depth. (Likely caused by pitting corrosion) **Advanced**: 41% - 70% depth. (Likely caused by pitting corrosion)

Severe Corrosion: 71% - 100% depth. (Likely caused by pitting corrosion)

After finding the low of 0.279" at 0'4" in the area of moderate internal corrosion as seen in the BP data, a larger UT area was requested to be inspected in this area. The UT area was made up, using a grid pattern, from the flange, axial direction up 15 inches and covered the circumferential direction 7" at the 0" mark and 3" at the 9" mark. This is shown in the following digital pictures.

Table-2, Summary of additional UT Measurements

Table 2 has been added showing the results of this UT inspection. The lowest UT measurement found here was 0.232" which is a 45% wall loss.

The axial distance starts at the flange and goes up 15 inches. Each square in the grid is 1.5" x 1.5".

Table 2
UT area at Circumference O" location

Axial	UT Low				
Distance	Reading	Reading	Reading	Reading	Reading
13.5"	0.277"	0.275"	0.270"	0.279"	0.281"
12"	0.376"	0.377"	0.372"	0.383"	0.384"
10.5"	0.292"	0.288"	0.292"	0.305"	0.300"
9"	0.315"	0.307"	0.300"	0.296"	0.308"
7.5"	0.332"	0.335"	0.317"	0.316"	0.306"
6"	0.341"	0.354"	0.315"	0.297"	0.295"
4.5"	0.330"	0.303"	0.315"	0.357"	0.381"
3.0"	0.366"	0.396"	0.345"	0.405"	0.430"
1.5"	0.380"	0.480"	0.375"	0.360"	0.341"

UT area at Circumference 9" location

Axial	UT Low	UT Low
Distance	Reading	Reading
13.5"	0.365"	0.306"
12"	0.294"	0.293"
10.5"	<mark>0.232"</mark>	0.276"
9"	0.255"	0.246"
7.5"	0.253"	0.258"
6"	0.269"	0.262"
4.5"	0.315"	0.316"
3.0"	0.368"	0.353"
1.5"	0.329"	0.320"

Note: The Axial distances used for these tables are started from the bottom flange.

Screen Captures: PR#23: Basin 4: Vertical 4





Figure 4. (Scan S01-01) BP data for a scan covering 48.0" to 0" to 4.5" circumference. (Probe centered at +0" position)



The image above has been labeled showing some of the signals confirmed with UT. The upper yellow area on the color map shows moderate corrosion. As noted, an additional UT grid was performed in this area (Table 2 on page 23).

Screen Captures: PR#23: Basin 4: Vertical 4





Figure 5. (Scan S02-01) BP data for a scan covering 4.5" to 13.5" circumference. (Probe centered at +9" position)



The image above has been labeled showing some of the signals confirmed with UT. The upper yellow area on the color map shows moderate corrosion.

Screen Captures: PR#23: Basin 4: Vertical 4





Figure 6. (Scan S05-01) BP data for a scan covering 48.0" to 0" to 4.5" circumference. (Probe centered at +36" position)



The image above has been labeled showing some of the signals confirmed with UT. The upper yellow area on the color map shows moderate corrosion.

Screen Captures: PR#23: Basin 4: Vertical 4





Figure 7. (Scan S06-01) BP data for a scan covering 40.5" to 49.5" circumference (Probe centered at 45" position).



The image above has been labeled showing some of the signals confirmed with UT. The upper yellow area on the color map shows moderate corrosion.

Digital Pictures: PR#23: Basin 4: Vertical 4





Figure A2. The picture above shows an overview of the pipe. 2 additional UT areas are shown near the bottom flange.

Digital Pictures: PR#23: Basin 4: Vertical 4





The pictures above show a closer view of the additional UT inspection areas on the pipe.

Inspection Test Site Details

Example Information for Day 1; for Gallery 2: Pipe Report # 2: Basin 4: Vertical 11

The Zero Foot Reference (ZFR) was set on the pipe, as shown in Figure A3. The ZFR was 0 foot 10 inches from the inside of the bottom end flange. Four scans were performed from 0" to +48.00". Note: Further set up details can be found in BP Report # 1.

Bracelet Probe TM (BP) data for this pipe was labeled as follows:

Bracelet Probe™ Inspection				
Scan Information	n			
Scan Identification	Probe Center	Circumference Distance (inches)	Scan Distance	Comments
S01-01	0	48.0 to 0 to 4.5	5′ 10″	ZFR is 10 inches from flange
S02-01	9	4.5 to 13.5		Not scanned – moved on
S03-01	18	13.5 to 22.5		Not scanned – moved on
S04-01	27	22.5 to 31.5		Not scanned – moved on
S05-01	36	31.5 to 40.5		Not scanned – moved on
S06-01	45	40.5 to 48.0		Not scanned – moved on

After scanning the first scan a corrosion area was found. UT inspection was performed in this area and it was determined to move on to a different pipe after confirming the corrosion area with a low UT measurement of 0.105".

All scans were performed with the flow direction. On the following pages the screen captures show some examples of the data scans. Some of these scans have also been labeled with arrows providing extra information.

Digital pictures showing the marking of the pipe have also been included.

Summary of Inspection Results: PR#2: Basin 4: Vertical 11

Table-1, Summary of Thickness Results

Circumference	Axial	Specified	UT Low	Scan
Location	Distance	Nominal	Reading	Number
0"	4"	0.420"	0.105"	S01-01
0"	5'8"	0.420"	0.405"	S01-01
0"		0.420"	0.160"	near flange
				_

Ultrasonic Thickness (UT) measurements at a few selected locations based on BP scan data are listed in Table 1.

UT = Ultrasonic Thickness.

The lowest UT measurement was 0.105" at 4".

The pipe at this location exhibits Severe internal corrosion (pitting) at 75%.

Calculation of % wall loss is against the record nominal, of Class 53, (0.420 wall").

The following scale is used for wall loss description:

Minor: up to - 20% depth. (Could be caused by mill tolerance)
Moderate: 21% - 40% depth. (Likely caused by pitting corrosion)
Advanced: 41% - 70% depth. (Likely caused by pitting corrosion)

Severe Corrosion: 71% - 100% depth. (Likely caused by pitting corrosion)

Screen Captures: PR#2: Basin 4: Vertical 11





Figure 8. (Scan S01-01) BP data for a scan covering 48.0" to 0" to 4.5" circumference. (Probe centered at +0" position)



The image above has been labeled showing some of the signals confirmed with UT. The upper yellow area on the color map shows moderate corrosion

Digital Picture: PR#2: Basin 4: Vertical 11




Figure A3. The picture above shows an overview of the pipe.

Digital Picture: PR#2: Basin 4: Vertical 11



The picture above shows a closer view of the UT confirmation area before being recoated.